



May 16, 2024

NATHAN J TRAVIS  
CASTLE PINES NORTH MD - PWSID CO0118006  
7404 YORKSHIRE DR  
CASTLE PINES CO 80109

### RESCIND OF TIER 1 BOIL WATER ADVISORY

Dear NATHAN J TRAVIS:

The Colorado Department of Public Health and Environment-Water Quality Control Division (the “Department”) issued a “Boil Water Advisory” for the CASTLE PINES NORTH MD (the “Supplier”) on **5/15/2024** due to a line break resulting in a loss of pressure to the system. Loss of pressure may allow disease-causing organisms to enter the water system.

Since the “Boil Water Advisory” was issued, the Department has received the following information from the Supplier:

- The Supplier flushed the system and average system chlorine residuals were brought down to normal levels after the flush.
- The Supplier provided a written description of flushing activities and confirmation that the lowest chlorine residual at the ends of the system.
- Confirmation that the samples taken were free from the presence of total coliform bacteria.

Based upon the actions taken by the Supplier, the “Boil Water Advisory” is hereby rescinded. Effective date of this action is **5/16/2024**. The affected customers should be notified of the lifting of the “Boil Water Advisory.” Public notice of the lifting of the “Boil Water Advisory” should include contact information for the water system and should be provided in a similar manner to which the initial advisory was issued. A template can be created at [wqcdcompliance.com/pn](http://wqcdcompliance.com/pn) under “Problem Corrected”.

Please note, rescindment of the “Boil Water Advisory” does not constitute compliance with public notification requirements. If not already completed, the Supplier must submit the certificate of delivery and copy of the original public notice to fulfill the regulatory public notification requirements for the “Boil Water Advisory”.

If you have any further questions, please contact me at 720-432-0589 or via email at [chelsea.cotton@state.co.us](mailto:chelsea.cotton@state.co.us).

Sincerely,

Chelsea Cotton

Lead Drinking Water Engineer  
Water Quality Control Division  
Colorado Department of Public Health and Environment

ec:

NATHAN J TRAVIS - NATHAN@CPNMD.ORG;  
SCOTT MONROE - WILLSEMOCOR@HOTMAIL.COM;  
SCOTT MONROE - WILLSEMOCOR@HOTMAIL.COM;  
CASTLE PINES NORTH MD {Owner Last Name} - NATHAN@CPNMD.ORG;  
Caitlin Gappa - cgappa@douglas.co.us; Douglas County Health Department  
Nicole Rowan, Water Quality Control Division Director, CDPHE  
Ron Falco, WQCD SDW Program Manager  
Nathan Moore, WQCD CW Program Manager  
Tyson Ingels, WQCD ES Manager  
Heather Young, WQCD FSS Manager  
Nicole Graziano, WQCD DWCAS Manager  
Jorge Delgado, WQCD DWCAS Compliance North Unit Manager  
Robert Pohl, WQCD DWCAS Compliance South Unit Manager  
MaryAnn Nason, WQCD Administrative Program Manager  
Kaitlyn Beekman, WQCD Communication Specialist  
Drinking Water Acute Response Team Leads, WQCD  
Sean Scott, DEHS, CDPHE  
Henry Mitchel. Office of Emergency Preparedness and Response, CDPHE  
Curt Drennen, Office of Emergency Preparedness and Response, CDPHE  
Korey Bell, Office of Emergency Preparedness and Response, CDPHE  
Pam Pergande, Office of Emergency Preparedness and Response, CDPHE  
Ria Fears, Office of Emergency Preparedness and Response, CDPHE  
Enteric Waterborne Disease Team, DCPHR, CDPHE  
Christina Postolowski, Mobile Home Park Oversight Program, DOLA, MHPOP@state.co.us  
Sam Fano - NORTH - C GW WQCD DWCAS Compliance Specialist

File: CO0118006, DOUGLAS, Community - Groundwater